



## Product certificate K109119/01

Issued 01-06-2022

Replaces -

Page 1 of 2

### Thermostatic Mixing Valves

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### DELABIE SCS

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K610 "Thermostatic mixing valves" dated 01-02-2012, which covers the requirements of:

EN1111:2017 "Sanitary tapware – Thermostatic Mixing Valves (PN10)".

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

Kiwa Nederland B.V.  
Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

Company  
DELABIE SCS  
18, rue, du Maréchal FOCH  
80130 FRIVILLE ESCARBOTIN  
France  
Tel. +33 322602270



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Thermostatic Mixing Valves

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this certificate

Type	Design	Article no.
Thermostatic mixing valve	Securitouch	H9769
	Securitouch	H9768
	Securitouch	H9768BEL
	Securitouch	H9768S
	Premix nano	732216
	Premix nano	732230

### FITNESS FOR CONTACT WITH DRINKING WATER

This products are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

### APPLICATION AND USE

Sanitary tapware; thermostatic mixing valves are designed for application within the following limits of use:

- a working pressure from 50 kPa up to 1000 kPa;
- a water temperature of maximum 90°C.

The recommended limits for correct operation are:

- a working pressure of 100 kPa up to 500 kPa;
- a water temperature of maximum 65°C.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" together with the Watermark logo 

Place of the mark: on the body.

Compulsory specifications:

- name or mark of manufacturer, on the body;
- indication for temperature selection, on the handle;
- the acoustic group, if classified, on the body;
- the flow rate class, on the body.

Method of marking:

- non-erasable;
- visible after assembly.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- DELABIE SCS
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.